

# AdvanceClean<sup>™</sup> EJC 100

**Product Data Sheet** 

www.chemadvances.com

### **Product Description**

AdvanceClean<sup>™</sup> EJC 100 is a concentrated water-dispersible, organic solvent-penetrant designed to remove polymerized glycol from the internal surfaces of engine and compressor cooling systems. The AdvanceClean<sup>™</sup> EJC 100 contains special organic solvents that work to penetrate porous or dense organic polymer or carbon deposits on the internal surfaces of the cooling system, removing them into the circulating fluid. A typical location for thermally degraded glycol deposits to form is in the piston liner area of an engine. Polymerized glycol sludge can clog cooling passages, ruin bearings, and glaze power cylinders from localized overheating. The thermal breakdown and polymerization of glycol can result from low fluid pH (less than pH 7.5) and a breakdown or depletion of corrosion inhibitors, leading to higher catalyzing metal content in the fluid. If your operating antifreeze coolant is black, you are experiencing a breakdown of the glycol in the system, and immediate attention is recommended. AdvanceClean<sup>™</sup> EJC 100 is safe for cleaning multi-metal systems typically found in stationary industrial engines and cooling systems.

## **Typical Physical Properties**

| Form@70°F             | Amber Liquid                   |
|-----------------------|--------------------------------|
| Appearance            | Clear Solution                 |
| Odor                  | Slight Aromatic                |
| Flash Point, °F (TCC) | 197° <b>F</b>                  |
| Density, (Ibs/gal)    | 8.4-8.5 (typical)              |
| Water Solubility      | Dispersible (milky dispersion) |
| Rinse Ability         | Complete with water.           |

## **Application Information**

AdvanceClean<sup>™</sup> EJC 100 should be diluted in water at 15% to 20% of circulating volume. The addition rate is relative to the severity of fouling within the system. In all cases, AdvanceClean<sup>™</sup> EJC 100 in water should be heated to a temperature between 160°F and 180°F and circulated throughout the system for optimal results. Circulating time will vary with a 4 to 6-hour period as typical. Circulation time varies with each application.

## Handling & Precautions

AdvanceClean<sup>™</sup> EJC 100 is available in 5-gal buckets, 55-gallon drums, and 275-gal one-way tote tanks. AdvanceClean<sup>™</sup> EJC 100 is an industrial chemical and should only be handled by those persons who have read and are familiar with the handling precautions provided in the product's safety data sheet.

1424 S Hugh Wallis Rd., Lafayette, Louisiana 70508 • www.chemadvances.com

Recommendations given in this bulletin are based on tests believed to be reliable. However, the use of the information is beyond the control of Chem Advances, LLC and no guarantee, expressed or implied is made to the results obtained if not used in accordance with directions or established safe practice. The buyer must assume all responsibility, including injury or damage from the misuse of the product as such, or in combination with other materials. This bulletin is not to be taken as a license to operate under or recommendation to infringe any patent.